



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • <http://www.cti.org>

October 14, 2021

Flow Tech Air Pvt. Ltd.
c/o Ritwick Das (ritwickdas@flowtechair.com)
B-105, Vishwakarma Colony
M.B.Road
New Delhi - 110044, India

Subject: Withdrawal of CTI Certification for Flow Tech Air Pvt. Ltd. FTA Product Line:

Gentlemen:

Referencing the initial CTI Certification Withdrawal notice dated September 1, 2021, the listed violations of CTI Certification Standard STD-201OM(19) have not been resolved by Flow Tech Air Pvt. Ltd. Further, the twenty (20) working day notification period has now expired, and no appeal has been filed with the CTI Board of Directors. Therefore, the CTI Certifications for the Flow Tech Air Pvt. Ltd. FTA counter-flow cooling tower line is withdrawn.

At this time you must immediately:

- a) cease using the CTI Certification Labels on models of the decertified lines;
- b) send written notification to all customers who purchased models of the lines while certified, but that have not been shipped by the date of withdrawal to notify them about the change in certification status; And,
- c) remove all reference to certification from the product brochures, published ratings, websites and other materials that pertain to the decertified lines.

Please review Section 8.7 and 8.8 of STD-201OM(19) for the remaining actions and notifications relative to withdrawal of CTI certification.

After a revocation period not to exceed one year, Flow Tech Air Pvt. Ltd. may reapply for CTI certification of your product line. However, the unresolved violations of the standard will have to be remedied (e.g. completion of overdue annual testing requirements) in order for the certifications to be reinstated.

If there are any questions regarding this letter or about the application of the STD-201 standard requirements, please contact me or Frank Michell (Board Liaison to the Certification Program Committee).

Sincerely,

Michael Womack, P.E.
CTI Thermal Certification Administrator
email: tcas@cleanair.com

cc: Virginia Manser, CTI Administrator
Chris Lazenby, CTI President
Frank Michell, Board Liaison to the Certification Program Committee