



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • <http://www.cti.org>

October 11, 2021

Truwater Cooling Towers Sdn Bhd
Executive Suite 702, Block B
Kelana Business Center
No 97, Jalan SS7/2, Kelana Jaya
47301 Petaling Jaya, Selangor, Darul Ehsan
Malaysia

Subject: Voluntary Withdrawal of CTI Cooling Tower Thermal Certification
TKS Series Closed-circuit Cooling Towers

Greetings:

This is to acknowledge that Truwater Cooling Towers Sdn Bhd (Truwater) has voluntarily withdrawn the TKS Series closed-circuit cooling tower line from the CTI Thermal Performance Certification Program, as set forth in CTI Certification Standard STD-201OM(19).

The line of TKS Series cooling towers had previously been assigned Certification Validation Number C41D-18R00. In accordance with CTI STD-201OM(19), the manufacturer:

- a. May use the Certification Label on all units from the certified line previously sold as CTI Certified, providing they ship within a 180 day period from the date of voluntary withdrawal;
- b. Shall not use the Certification Label on any new units sold after the date of the voluntary withdrawal;
- c. Shall remove all references to CTI Certification from the product brochures, published ratings, product drawings, and other literature pertaining to the withdrawn line within 120 days of the date of the voluntary withdrawal.

If there are any questions regarding the procedures listed above, please contact me.

Very truly yours,

A handwritten signature in black ink that reads 'Michael Womack'.

Michael G. Womack, PE
CTI Thermal Certification Administrator